

Microbiological	Highest Number of Positive Samples	MCL		MCLG		Likely Source of Contamination		Violations Present
No Detected Results were Found in the Calendar Year of 2025								
Lead and Copper	Monitoring Period	90 th Percentile	Range	Unit	AL	Sites Over AL	AL	Likely Source of Contamination
COPPER, FREE	2022 - 2024	0.4595	0.0873 - 0.568	ppm	1.3	0		Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.
LEAD	2022 - 2024	6.8	0 - 7.4	ppb	15	0		Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing.
Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Likely Source of Contamination	
BARIUM	2/14/2024	0.11	0.11	ppm	2	2	Discharge from drilling wastes; Discharge from metal refineries; Erosion of natural deposits.	
FLUORIDE	2/14/2024	0.312	0.312	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; Fertilizer discharge.	
NITRATE-NITRITE	8/28/2025	1	1	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	
SELENIUM	2/14/2024	3.7	3.7	ppb	50	50	Erosion of natural deposits	
Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Likely Source of Contamination	
COMBINED RADIUM (-226 & -228)	10/27/2023	0.806	0.806	pCi/L	5	0	Erosion of natural deposits	
RADIUM-228	10/27/2023	0.806	0.806	pCi/L	0	0	Erosion of natural deposits	
Unregulated Water Quality Data	Collection Date	Highest Value	Range	Unit	Secondary MCL			
SULFATE	8/23/2023	11.4	11.4	mg/L	250			

During the 2025 calendar year, we had the below noted violation(s) of drinking water regulations.

Violation Type	Category	Analyte	Compliance Period
No Violations Occurred in the Calendar Year of 2025			

Uncorrected Significant Deficiencies			
Date Identified	Facility	Category Code	Category Description
07/10/2025	WATER SYSTEM	2247	22-004 Item 7e - Failure to require cross-connection surveys
07/10/2025	WATER SYSTEM	2270	22-005 Item 2 - Failure to maintain equipment in accordance to manufacturer's specifications
07/10/2025	WATER SYSTEM	2330	22-006 Item 1 - Well sanitary seal not maintained
07/12/2022	WATER SYSTEM	2360	22-006 Item 13 - PWS facilities not maintained in a clean, orderly, and accessible manner

The Village of Alvo has taken the following actions to address the deficiencies listed above:

There are no additional required health effects notices.

There are no additional required health effects violation notices.

The Village of Alvo lead service line inventory has been prepared and can be accessed here: _____



Village of Alvo

Annual Water Quality Report For January 1 to December 31, 2025

This report is intended to provide you with important information about your drinking water and the efforts made by the Village of Alvo water system to provide safe drinking water.

Para Clientes Que Hablan Español: Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo o hable con alguien que entienda bien.

For more information regarding this report, or to request a hard copy, contact:

MIKE ADAIR
402-677-3781

If you would like to observe the decision-making processes that affect drinking water quality, please attend the regularly scheduled meeting of the Village Board/City Council. If you would like to participate in the process, please contact the Village/City Clerk to arrange to be placed on the agenda of the meeting of the Village Board/City Council.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791).

Source Water Assessment Availability:

The Nebraska Department of Water, Environment, and Energy (DWEE) has completed the Source Water Assessment. Included in the assessment are a Wellhead Protection Area map, potential contaminant source inventory, and source water protection information. To view the Source Water Assessment or for more information please contact the person named above on this report or the DWEE at 402-471-3376 or 402-471-9249 or go to <http://dee.ne.gov>.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Sources of Drinking Water:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals

and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

The source of water used by Village of Alvo is ground water.

Contaminants that may be present in source water include:

- * Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- * Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- * Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- * Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- * Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Drinking Water Health Notes:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Village of Alvo is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact MIKE ADAIR, 402-677-3781. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

The Village of Alvo is required to test for the following contaminants: *Citiform Bacteria*, *Antimony*, *Arsenic*, *Asbestos*, *Barium*, *Beryllium*, *Cadmium*, *Chromium*, *Copper*, *Cyanide*, *Fluoride*, *Lead*, *Mercury*, *Nickel*, *Nitrate*, *Nitrite*, *Selenium*, *Sodium*, *Thallium*, *Atachlor*, *Atrazine*, *Benzo(a)pyrene*, *Carbofuran*, *Chloroform*, *Dalapon*, *Dl(2-ethylhexyl)adipate*, *Dibromochloropropane*, *Dinoseb*, *Dl(2-ethylhexyl)-phthalate*, *Diquat*, *2,4-D*, *Endothal*, *Endrin*, *Ethylene dibromide*, *Glyphosate*, *Hepachlor*,

Heptachlor epoxide, *Hexachlorobenzene*, *Hexachlorocyclopentadiene*, *Lindane*, *Methoxychlor*, *Oxamyl* (Vydate), *Pentachloropentadiene*, *Polychlorinated biphenyls*, *Simazine*, *Toxaphene*, *Dioxin*, *Silvex*, *Benzene*, *Carbon Tetrachloride*, *o-Dichloro-benzene*, *Para-Dichlorobenzene*, *1,2-Dichloroethane*, *1,1-Dichloroethylene*, *Cis-1,2-Dichloroethylene*, *Trans-1,2-Dichloroethylene*, *Dichloromethane*, *1,2-Dichloropropane*, *Ethylbenzene*, *Monochlorobenzene*, *1,2,4-Trichloro-benzene*, *1,1,1-Trichloroethane*, *1,1,2-Trichloroethane*, *Trichloroethylene*, *Vinyl Chloride*, *Styrene*, *Tetrachloroethylene*, *Toluene*, *Xylenes* (total), *Gross Alpha* (minus Uranium & Radium 226 plus Radium 228, Sulfate, Chloroform, Bromodichloromethane, Chlorodibromomethane, Bromoform, Chlorobenzene, m-Dichlorobenzene, 1,1-Dichloropropane, 1,1-Dichloroethane, 1,1,2,2-Tetrachloroethane, 1,2-Dichloropropane, Chloromethane, Bromomethane, 1,2,3-Trichloropropane, 1,1,1,2-Tetrachloroethane, Chloroethane, 2,2-Dichloropropane, o-Chlorotoluene, p-Chlorotoluene, Bromobenzene, 1,3-Dichloropropane, Aldrin, Butachlor, Carbyl, Dicamba, Dieldrin, 3-Hydroxycarbofuran, Methomyl, Metolachlor, Methabuzin, Propachlor.

How to Read the Water Quality Data Table:

The EPA and State Drinking Water Program establish the safe drinking water regulations that limit the amount of contaminants allowed in drinking water. The table shows the concentrations of detected substances in comparison to the regulatory limits. Substances not detected are not included in the table. The state requires monitoring of certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Therefore, some of this data may be older than one year.

MCL (Maximum Contaminant Level) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

AL (Action Level) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MMDL (Maximum Residual Disinfectant Level) – The highest level of a disinfectant allowed in drinking water.

M/A – Not applicable.

Units in the Table:

ND – Not detectable.

ppm (parts per million) – One ppm corresponds to 1 gallon of concentrate in 1 million gallons of water.

mg/L (milligrams per liter) – Equivalent to ppm.

ppb (parts per billion) – One ppb corresponds to 1 gallon of concentrate in 1 billion gallons of water.

ug/L (micrograms per liter) – Equivalent to ppb.

PC/L (Picoocuries per liter) – Radioactively concentration unit.

RAA (Running Annual Average) – An ongoing annual average calculation of data from the most recent four quarters.

LRAA (Locational Running Annual Average) – An ongoing annual average calculation of data from the most recent four quarters at each sampling location.

90th Percentile – Represents the highest value found out of 90% of the samples taken in a representative group. If the 90th percentile is greater than the action level, it will trigger a treatment or other requirements that a water system must follow.

TT (Treatment Technique) – A required process intended to reduce the level of a contaminant in drinking water.

Consumer Confidence Report Certification of Distribution for 2025

PWS Name: **Village of Alvo**
Population Served: **142**

Account Number: **NE3102508**
County: **Cass**

CCR Distribution and CCR paperwork submittal are due no later than July 1, 2026.

You must use one or more direct delivery method to reach every bill paying customer. Good Faith delivery methods must be used to reach non-bill paying customers. Systems are required to maintain copies of CCRs to be available upon public request.

Direct Delivery Methods (Must use at least one of these methods):

Please provide the date(s) CCRs were distributed on lines provided below

Mail a paper copy of the CCR. (Distribution date: 3-31-2026)

Publish CCR. (Publish date: _____ . Send in a copy of the newspaper clipping of the CCR with this Certification.)

Mail notification that the CCR is available online at the Internet address below. (Posting date: _____)
(The internet link must take the customer directly to the open CCR.)

Email notification that the CCR is available online at the Internet address below. (Posting date: _____)
(The internet link must take the customer directly to the open CCR.)

Email CCR as an attachment or an embedded image in an email. (Distribution date: _____)

Posting the CCR in public places. List the three (3) posting locations below. (Posting date: 3-31-2026)

1) Village office 135 Main Street 2) _____ 3) _____
(Note: Public water systems serving a population of 500 or less may elect to distribute CCRs by posting only.)

Electronic delivery method at the Internet address below. (Posting date: _____)
Please provide URL: http://_____

Good Faith Delivery methods (to reach people who do not receive bills) 100% of system customers received mailing

Please provide the date(s) CCRs were distributed below with the corresponding methods:

Mailing the CCR to people who receive mail, but do not receive bills. (Distribution date: 3-31-2026) *Church and inactive customers and businesses in town*

Advertising the availability of the CCR in news media. (Distribution date: _____)

Delivering multiple copies to business addresses serving multiple persons. (Distribution date: _____)

Delivering copies of the CCR to community organizations (such as local health departments). (Distribution date: _____)

If your system is a wholesale water system which sells water to consecutive water systems, please answer the following question:

Were consecutive systems notified? Yes No If yes, who? _____

The community water system named above hereby affirms that the Annual Water Quality Report (i.e., Consumer Confidence Report) has been distributed to customers (and appropriate notices of availability have been given) in accordance with Nebraska's Regulations Governing Public Water Supply Systems, Title 179 NAC 14. Further, this certifies that the information contained in the report is correct and consistent with the compliance monitoring data received by Nebraska Department of Water, Environment, and Energy.

Certified By: **Name (Print)** Alvo Snell **Signature:** Alvo Snell **WO License Number:** Brad #5369

Phone: 402-430-0189 **Email:** greenlightofnebraska@gmail.com **Date:** 3-31-2026

Working under Brad Mc Cleary WO # 5369